

Bloomfield Borough Water Authority

PWSID #7500012



2022 Annual Water Quality Report

Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, ó hable con alguien que lo entienda.

(This report contains important information about your drinking water. Have someone translate it for you, or speak with someone who understands it.)

WATER AUTHORITY INFORMATION

This report shows our water quality and what it means. If you have any questions about this report or concerning your water utility, please contact Larry Fisher at (717) 582-3382. We want you to be informed about your water supply. If you want to learn more, please attend any of our regularly scheduled monthly meetings. They are held at the Bloomfield Borough building at 7:00 P.M. on the 4th Tuesday of every month.

SOURCES OF WATER

Entry Point (EP) 102: BBWA Well 1 (003) – Mahanoy Ridge

BBWA Well 2 (004) – Mahanoy Ridge

Perry Village Well 2 (007) – 213 E. Main St

Entry Point (EP) 104: BBWA Well 3 (008) – 163 Jeanne Fry Lane

VULNERABILITY

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791.

MONITORING

The Bloomfield Borough Water Authority routinely monitors for contaminants in your drinking water according to federal and state laws. The following table shows the results of our monitoring for the period of January 1 to December 31, 2022. The state allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data is from prior years in accordance with the Safe Water Drinking Act. The date has been noted on the sampling results table.

DEFINITIONS

Action Level (AL) – The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) – The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Minimum Residual Disinfectant Level (MinRDL) – The minimum level of residual disinfectant required at the entry point to the distribution system.

Treatment Technique (TT) – A required process intended to reduce the level of a contaminant in drinking

Nephelometric Turbidity Unit (NTU) – A measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

ppb = parts per billion, or micrograms per liter (µg/L)

ppm = parts per million, or milligrams per liter (mg/L)

pCi/L = picocuries per liter (a measure of radioactivity)

Chemical Contaminants								
Contaminant	MCL in CCR Units	MCLG	Level Detected	Range Of Detections	Units	Sample Date	Violation Y / N	Sources Of Contamination
Nitrate – EP 102	10	10	0.337	0 - 0.337	ppm	8-12-2022	N	Fertilizer runoff; leaking septic tank; erosion of natural deposits
Nitrate – EP 103	10	10	1.88	0 – 1.88	ppm	8-12-2022	N	Fertilizer runoff; leaking septic tank; erosion of natural deposits
Nitrate – EP 104	10	10	5.55	4.52 – 5.55	ppm	2-17-2022	N	Fertilizer runoff; leaking septic tank; erosion of natural deposits
Trihalomethanes TTHM	80	-	0.018	0.00276 – 0.018	ppb	12-7-2022	N	Byproduct of drinking water disinfection
Haloacetic Acids	60	-	0.00449	0.00109 – 0.00449	Ppb	12-7-2022	N	Byproduct of drinking water disinfection
Gross Alpha – EP 104	15	-	4.26	0 – 4.26	pCi/L	11-2-2022	N	Erosion of natural deposits

Entry Point Disinfectant Residual							
Contaminant	Minimum Disinfectant Residual	Lowest Level Detected	Highest Level Detected	Units	Sample Date	Violation Y / N	Sources Of Contamination
Chlorine – EP 102	0.40	0.55	2.8	ppm	8-14-2022	N	Water additive to control microbes
Chlorine – EP 103	0.40	0.60	1.88	ppm	10-8-2022	N	Water additive to control microbes
Chlorine – EP 104	0.20	0.004	2.00	ppm	3-1-2022	Y	Water additive to control microbes

Distribution Disinfectant Residual

Contaminant	Month of highest Ave Result	Highest Ave Result	MRDL	Over MRDL	Lowest Ave. Result	Unit of Measure
Chlorine	March	1.12	4.0	N	0.59	MG/L

Microbial

Contaminants	MCL	MCLG	Highest # or % Of Positive Samples	Violation Y/N	Sources Of Contamination
Total Coliform Bacteria	For systems that collect <40 samples / month: *More than 1 positive monthly sample	0	0	N	Naturally present in the environment
Fecal Coliform Bacteria or E.Coli	0	0	0	N	Human and animal fecal waste

Lead and Copper 2022

Contaminant	Action Level (AL)	MCLG	90 th Percentile Value	Units	# of Sites Above AL of Total Sites	Violation Y/N	Sources of Contamination
Lead	0.015	0	0.0044	ppb	0 out of 15	N	Corrosion of household plumbing.
Copper	1.3	1.3	0.705	ppm	0 out of 15	N	Corrosion of household plumbing.

Turbidity

PWSID	Plant Name	Sample Month	Number of Measurements	Number of Measurements Meeting PLR	Percent of Measurements Meeting PLR	Highest Individual Value (NTU)
7500012	Membrane Plant	January	447	447	100	-
7500012	Membrane Plant	February	207	207	100	-
7500012	Membrane Plant	March	455	455	100	-
7500012	Membrane Plant	April	429	429	100	-
7500012	Membrane Plant	May	456	456	100	-
7500012	Membrane Plant	June	352	352	100	-
7500012	Membrane Plant	July	407	407	100	-
7500012	Membrane Plant	August	512	512	100	-

7500012	Membrane Plant	September	396	396	100	-
7500012	Membrane Plant	October	396	396	100	-
7500012	Membrane Plant	November	404	404	100	-
7500012	Membrane Plant	December	480	480	100	-

HEALTH EFFECTS

About Nitrate: Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity.

About TTHM's (total Trihalomethanes): Some people who drink water containing Trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys or central nervous systems, and may have an increased risk of getting cancer.

About HAA's (Haloacetic Acids): Some people who drink water containing Haloacetic Acids in excess of the MCL over many years have an increased risk of getting cancer.

OTHER VIOLATIONS

*Referencing table above "Entry Point Disinfectant Residual," Lowest Level Detected of 0.004 ppm on March 1, 2022 was a temporary computer glitch during plant shutdown. There was no way physically for the numbers to change that quickly in 15 minutes. This was reported to DEP. No further action required.

*EP – 104 sampling for SOCs, RADs, Alpha/Excl. Radon, Uranium, Combined Uranium were not reported in the 2nd quarter due to a lab error in which the samples arrived out of hold time due to internal lab delays. Reference violation ID's 32424, 32425, 32426, 32427, 32428, 32420, 32421, 32422 and 32423. Sampling will be taken in 2nd quarter of 2023. A letter from the lab acknowledging their error is on file.

EDUCATIONAL INFORMATION

All sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater run-off, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

· Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and DEP prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA and DEP regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's *Safe Drinking Water Hotline* at (800) 426-4791.

INFORMATION ABOUT LEAD

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Bloomfield Borough Water Authority is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Water Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.



PUBLIC NOTICE

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER FAILURE TO MONITOR

**ESTE INFORME CONTIENE INFORMACIÓN IMPORTANTE ACERCA DE SU AGUA POTABLE. HAGA QUE
ALGUIEN LO TRADUZCA PARA USTED, O HABLE CON ALGUIEN QUE LO ENTIENDA.**

Monitoring Requirements Not Met for Bloomfield Borough Water Authority

Our water system violated several drinking water standards over the past year. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 2022 we failed to monitor for the following contaminants and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the contaminant(s) we did not properly test for during the last year, the required sampling frequency, how many samples we took, when samples should have been taken, and the date on which corrective action samples were (or will be) taken.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	When samples were or will be taken
SOC	Quarterly	None	2 nd Quarter	2 nd Quarter 2023
RAD	Quarterly	None	2 nd Quarter	2 nd Quarter 2023
Uranium	Quarterly	None	2 nd Quarter	2 nd Quarter 2023

What happened? What was done? When will it be resolved?

Microbac Lab mishandled samples and were not submitted timely for 2nd quarter of 2022. Sampling will be done in 2nd quarter of 2023.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For more information regarding this notice, please contact Larry Fisher at 717-582-3382.

Certified by:

Signature: 

Date: 05-08-23

Print Name and Title: Larry Fisher, Plant Operator

As a representative of the Public Water system indicated above, I certify that public notification addressing the above violation was distributed to all customers in accordance with the delivery requirements outlined in Chapter 25 PA Code 109 Subchapter D of the Department of Environmental Protection (DEP's) regulations. The following methods of distribution were used: Mail

PWS ID#: 7500012

Date distributed: June 2023



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF SAFE DRINKING WATER

PUBLIC NOTICE

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
FAILURE TO MONITOR**

**ESTE INFORME CONTIENE INFORMACIÓN IMPORTANTE ACERCA DE SU AGUA POTABLE. HAGA QUE
ALGUIEN LO TRADUZCA PARA USTED, O HABLE CON ALGUIEN QUE LO ENTIENDA.**

Monitoring Requirements Not Met for Bloomfield Borough Water Authority

Our water system violated several drinking water standards over the past year. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 2022 we failed to monitor for the following contaminants and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the contaminant(s) we did not properly test for during the last year, the required sampling frequency, how many samples we took, when samples should have been taken, and the date on which corrective action samples were (or will be) taken.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	When samples were or will be taken
Combined Uranium	Quarterly	None	2 nd Quarter	2 nd Quarter 2023
Alpha/Excl. Radon	Quarterly	None	2 nd Quarter	2 nd Quarter 2023

What happened? What was done? When will it be resolved?

Microbac Lab mishandled samples and were not submitted timely for 2nd quarter of 2022. Sampling will be done in 2nd quarter of 2023.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For more information regarding this notice, please contact Larry Fisher at 717-582-3382.

Certified by:

Signature: *[Handwritten Signature]*

Date: 05-08-23

Print Name and Title: Larry Fisher, Plant Operator

As a representative of the Public Water system indicated above, I certify that public notification addressing the above violation was distributed to all customers in accordance with the delivery requirements outlined in Chapter 25 PA Code 109 Subchapter D of the Department of Environmental Protection (DEP's) regulations. The following methods of distribution were used: Mail

PWS ID#: 7500012

Date distributed: June 2023